

Message

From: Hanchett, James (DPH) [/O=COMMONWEALTH OF MASSACHUSETTS/OU=MASSMAIL-01/CN=RECIPIENTS/CN=JAMES.HANCHETT]
Sent: 9/20/2012 1:40:16 PM
To: 'Ewart, Burt' [bewart@facil.umass.edu]
Subject: Exhuast Problem

Hi Burt,

You had a problem yesterday with Vivarium exhaust fans. It caused negative pressure in N236. That was the only room affected. We must be connected above ceiling to fish lab. Why else would N236 only be affected?

Jim Hanchett
Department of State Police
Amherst Drug Lab
Room N251 Morrill I
637 North Pleasant Street
Amherst, MA 01003
Phone 413-545-2607
Fax 413-545-2608
Cell [REDACTED]